

Date of Incident	01-10-2021
Prepared By	Herbert Turner
Reviewed By	Incident Report was reviewed by Lori Kolinchak on 01-11-2021 at 09:28 AM.
Property	Mt. Airy Arms
Time of Incident	11:30:00
Location of Incident	Boiler room

Description of Incident
Water on floor
Corrective action taken at the time of the incident
Contacted Mike Jacobus. Turned off boiler and power. L&L contacted and responded. Cracked cell inside old boiler to be repaired 1/11/21.
What we have done related to Customer Service and helping the resident, if anything?
notified that boiler will be down for a few hours
Witnesses names and phone number
Newton Williams 2157402076
Is criminal activity involved
No
Was there security camera footage of this incident?
No
Link to security footage video in Box
http://
Did this incident involve a resident?
No
Did this incident involve a Lindy team member?
No
Did this incident involve a vendor?
No

