

<b>Date of Incident</b>	03-22-2021
<b>Prepared By</b>	Josh Kozich
<b>Reviewed By</b>	Incident Report was reviewed by Brian Kroker on 03-22-2021 at 11:27 AM.
<b>Property</b>	Towers at Wyncote
<b>Time of Incident</b>	10:58:00
<b>Location of Incident</b>	1219-2

Description of Incident
Broken Toilet supply line in 1219-2 causing water to leak all the way to the maintenance shop. Called out Disaster Solutions to address issues in all apartments in that stack
Corrective action taken at the time of the incident
Fixed toilet supply line in 1219-2 and called out Disaster Solutions to fix any water related damage.
What we have done related to Customer Service and helping the resident, if anything?
Fixed toilet supply line. Disaster Solutions to follow up with remediation of any damages.
Witnesses names and phone number
Vlad - maintenance
Is criminal activity involved
No
Was there security camera footage of this incident?
No
Link to security footage video in Box
http://
Did this incident involve a resident?
No
Did this incident involve a Lindy team member?
No
Did this incident involve a vendor?
No

