

|                             |   |
|-----------------------------|---|
| <b>Date of Incident</b>     | 09-06-2022  |
| <b>Prepared By</b>          | Joe Cooper  |
| <b>Reviewed By</b>          | Incident Report was reviewed by Joe Cooper on 09-07-2022 at 08:23 AM. |
| <b>Property</b>             | Towers at Wyncote   |
| <b>Time of Incident</b>     | 09:00:00  |
| <b>Location of Incident</b> | Building one restaurant fountain                                      |

| Incident Type  |
|--|
| Misc.  |
| Description of Incident  |
| The pump room for fountain out front of building one became flooded do to heaven rain. The internal pump was unable to keep up with the influx of water. |
| Corrective action taken at the time of the incident  |
| Pump and equipment shut down excluding drain pump. Cones set up around area to keep residents away.  |
| What we have done related to Customer Service and helping the resident, if anything?   |
| Cones set up to keep area clear.   |
| Witnesses names and phone number   |
| Alex T 215-869-4908  |
| Was there security camera footage of this incident?  |
| No   |
| Link to security footage video in Box  |
| http://  |
| Did this incident involve a resident?  |
| No   |
| Did this incident involve a Lindy team member?   |
| No   |
| Did this incident involve a vendor?  |
| No   |

