



Date of Incident	12-07-2021
Prepared By	Paul Oneto
Reviewed By	Incident Report was reviewed by Adrinne Rose on 12-09-2021 at 08:05 PM.
Property	Meadowbrook
Time of Incident	04:05:00
Location of Incident	100, leasing, 300, half of 400, half oh 500, one building in the 600, half of 800, and 900 section

Description of Incident
Around 4:05 pm on December 7th we lost power. Henkels and McCoy were called out. They found another underground fault between transformers 1469 and 1576. That is in between units 842 and 966. The residents were notified and the power was restored around 5pm that night.
Corrective action taken at the time of the incident
Called contractors and notified residents
What we have done related to Customer Service and helping the resident, if anything?
Reassured them we would get the power back on ASAP.
Witnesses names and phone number
Paul 267-431-5541
Is criminal activity involved
No
Was there security camera footage of this incident?
No
Link to security footage video in Box
http://
Did this incident involve a resident?
No
Did this incident involve a Lindy team member?
No
Did this incident involve a vendor?
No

