



Make Ready Checklist Inspection

Inspection Date	Technician	Property	Units
09-16-2022	Maurice Duckson	Towers at Wyncote	0813-1

LIVING ROOM:	
Plank Flooring:	Not Ok
Charges Type	
Charges	0
Comment	Needs to be swept and mopped

DINING ROOM:	
Ceilings / Lights:	Ok
Plank Flooring:	Not Ok
Charges Type	
Charges	0
Comment	Tile floors need to be swept and mopped
Walls / Outlets:	Ok
Window:	Ok
Window coverings:	Ok

KITCHEN:	
Backsplash:	Ok
Cabinets:	Ok
Ceiling Fan:	Ok
Ceiling Light Fixture:	Ok
Ceiling Lights:	Ok
Cleaning of Stove:	Not Ok
Charges Type	
Charges	0
Counter Top:	Ok

Dishwasher:	Ok
Drip Pan:	Ok
Electric Meter:	Ok
Faucet:	Ok
Faucet Knobs:	Ok
Floors:	Not Ok
Charges Type	
Charges	0
Comment	Need to be swept and mopped
Formica/Tiles:	Ok
Garbage Disposal:	Ok
Kitchen Sink:	Ok
Microwave:	Not Ok
Charges Type	
Charges	0
Comment	Needs to be cleaned



Other:	Not Ok
Charges Type	
Charges	0
Comment	Cabinets badly worn. Needs to be touched up.



Oven / Range:	
Oven Cleaning:	Not Ok
Charges Type	
Charges	0
Comment	Needs to be thoroughly cleaned



Oven / Range:	
Oven door handle:	Ok

Oven / Range:	
Oven drip pan:	Ok

Oven / Range:	
Oven knobs:	Ok

Oven / Range:	
Oven Racks:	Ok

Oven / Range:	
Range burners:	Ok

Oven / Range:	
Range Hood:	Ok

Oven Door Handle:	Ok
Oven Racks:	Ok
Range Top:	Ok

Refrigerator (Freezer):	
Cleaning Refrigerator:	Not Ok
Charges Type	
Charges	0
Comment	Exterior needs to be thoroughly cleaned



Refrigerator (Freezer):	
Refrigerator (Drawers):	Ok

Refrigerator (Freezer):	
Refrigerator (Shelf and Bars):	Not Ok
Charges Type	
Charges	0
Comment	Looks to be broken





Refrigerator (Freezer):	
Refrigerator Crisper Glass/Plastic:	Ok
Rubber Stopper:	Ok
Stove Knob:	Ok
Verify that either a Fire Stop (under the microwave) or FireAvert (behind the stove) exists.:	Ok
Wall Outlets:	Ok
Washer/Dryer:	Ok
Window Coverings:	Ok

BEDROOMS:	
Ceilings / Lights:	Ok
Door / Closet:	Ok
Floors / Carpet:	Ok
Other:	Not Ok
Charges Type	
Charges	0
Comment	Doorway to secondary entrance has gap




Plank Flooring:	Ok
Walls / Outlets:	Ok
Window:	Ok
Window coverings:	Ok

BATHROOM:	
Cabinets / Mirror:	Not Ok
Charges Type	
Charges	0


Comment	Cabinets worn
	
Ceiling Lights:	Ok
Cleaning Bathroom:	Not Ok
Charges Type	
Charges	0
Comment	First bathroom by entry door shower tiles dirty Standup shower stall in second bathroom dirty.
	
Complete Toilet:	Ok
Counter Top:	Ok
Floors:	Ok
Formica /Tile:	Ok
Is there signs of moisture from outside in the apartment?:	Ok
Medicine Cabinet:	Ok
Mirror Cabinet:	Ok
Other:	Not Ok
Charges Type	
Charges	0
Comment	Secondary bedroom bathroom cabinets are worn



Plank Flooring:	Not Ok
Charges Type	
Charges	0
Comment	Tile floor in first bedroom by entrance door needs to be mopped.



Remove Mildew on Tiles:	Ok
Shower Curtain Bar:	Ok
Shower Head:	Not Ok
Charges Type	
Charges	0
Comment	Shower head in second bathroom dripping



Sink:	Ok
-------	----

Soad Dish (Tub):	Ok
Soap Dish (Sink):	Ok
Toilet Paper Holder:	Ok
Toilet Tank:	Ok
Towel Bar:	Ok
Tub Knob(s):	Ok
Tub Reglazing:	Ok
Vanity Cabinet:	Ok
Wall Outlets:	Ok
Window:	Ok

LOCKS:	
Door Knob:	Ok
Door Lock:	Ok
Ensure the apartment door has an automatic closure and closes properly. :	Ok
Fix Door when extra lock is removed:	Ok
Mail-Box Lock:	Ok

KEYS:	
Failure To Return Apartment Key:	Ok
Failure To Return Mailbox Key:	Ok

DOORS:	
Apartment Door:	Ok
Apartment Door closes automatically:	Ok
Frame:	Ok
Hollow:	Ok
Solid Core & Steel:	Ok

PAINTING:	
Border Removal (Per Room):	Ok
Holes in Walls (Each Hole):	Ok
Over Dark Colors (Per Room):	Ok
Wallpaper Removal (Per Room):	Ok

CARPET:	
----------------	--

Burns:	Ok
Deodorize:	Ok
Pet Treatment (Odor):	Ok
Replace Carpet 1 Bedroom:	Ok
Replace Carpet 2 Bedroom:	Ok
Shampoo 1 Bedroom:	Ok
Shampoo 2 Bedroom:	Ok
Stain Removal:	Ok


MISCELLANEOUS:	
Broken Window Glass (Per Pane):	Ok
Cabinet Equipment:	Ok
Carbon Monoxide Detector:	Ok
Cleaning of Apartment:	Ok
Clear Storage Locker:	Ok
Closet Shelves:	Ok
Common Area damaged during moveout:	Ok
Confirm you have installed or there is in place a stainless steel toilet tank water connector.:	Ok
Door Intercom System:	Ok
Exhaust Fan:	Ok
Fan Blades:	Ok
Fire extinguisher:	Ok
If fire stops have been installed throughout the property, ensure fire stops are installed.:	Ok
Light Globes:	Ok
Mini Blind(s) each:	Ok
Outside Lights:	Ok
Phone Jack:	Ok
Rallings:	Ok
Removal Of Bulk Items:	Ok
Remove Debris (Per Bag):	Ok
Sliding Mirror/Glass Door (2):	Ok
Smoke Detector Alarm:	Ok
Stoppage by foreign object in any drain:	Ok
Switch Plate Covers:	Ok

Thermostat Cover:	Ok
Vertical Blinds:	Ok
Vinly Tile Bathroom:	Ok
Vinly Tile Kitchen:	Ok
Window Screen(s) each:	Ok
Window Sills:	Ok

OVERALL:	
Signs of Moisture inside the apartment:	Ok
Signs of Moisture outside the apartment:	Ok

Resident	
----------	--

Lindy Community Representative Name	Maurice Duckson
-------------------------------------	-----------------



Technician	Maurice Duckson
Resident not available for signature	
Resident refused Signature	