

## **Make Ready Checklist Inspection**

| Inspection Date | Technician    | Property      | Units |
|-----------------|---------------|---------------|-------|
| 11-08-2022      | Cianni Hudson | Regency House | 209   |

| LIVING ROOM:       |    |
|--------------------|----|
| Ceilings / Lights: | Ok |
| Door / Closet:     | Ok |
| Other:             | Ok |
| Walls / Outlets:   | Ok |
| Window:            | Ok |
| Window coverings:  | Ok |

| DINING ROOM:       |    |
|--------------------|----|
| Ceilings / Lights: | Ok |
| Walls / Outlets:   | Ok |
| Window:            | Ok |
| Window coverings:  | Ok |

| KITCHEN:               |    |
|------------------------|----|
| Backsplash:            | Ok |
| Ceiling Fan:           | Ok |
| Ceiling Light Fixture: | Ok |
| Ceiling Lights:        | Ok |
| Cleaning of Stove:     | Ok |
| Counter Top:           | Ok |

| Dishwasher:      |    |
|------------------|----|
| Dishwasher Knob: | Ok |

| Dishwasher Rack:              | Ok |              |
|-------------------------------|----|--------------|
|                               |    |              |
| Dishwasher:                   |    |              |
| Dishwasher Silverware Holder: |    | Ok           |
| Drip Pan:                     |    | Ok           |
| Electric Meter:               |    | Ok           |
| Faucet:                       |    | Ok           |
| Faucet Knobs:                 |    | Ok           |
| Floors:                       |    | Not Ok       |
| Charges Type                  |    |              |
| Charges                       |    | 0            |
| Comment                       |    | Need cleanin |
| Formica/Tiles:                |    | Ok           |
| Garbage Disposal:             |    | Ok           |
| Kitchen Sink:                 |    | Ok           |
| Microwave:                    |    | Ok           |
| Other:                        |    | Ok           |
| Oven / Range:                 |    |              |
| Oven Cleaning:                | Ok |              |
| Oven / Range:                 |    |              |
| Oven door handle:             | Ok |              |
| Oven / Range:                 |    |              |
| Oven drip pan:                | Ok |              |
| Oven / Range:                 |    |              |
| Oven knobs:                   | Ok |              |
| Oven / Range:                 |    |              |
| Oven Racks:                   | Ok |              |
| Oven / Range:                 |    |              |
| Range burners:                | Ok |              |

| Oven / Range:   |        |
|---|--------|
| Range Hood:   | Ok     |
| Oven Door Handle:   | Ok     |
| Oven Racks:   | Ok     |
| Range Top:  | Ok     |
| Rubber Stopper:   | Ok     |
| Stove Knob:   | Ok     |
| Verify that either a Fire Stop (under the microwave) or FireAvert (behind the stove) exists | S.: Ok |
| Wall Outlets:   |        |
| Washer/Dryer:   | Ok     |
| Window Coverings:   | Ok     |

| BEDROOMS:          |    |
|--------------------|----|
| Ceilings / Lights: | Ok |
| Door / Closet:     | Ok |
| Floors / Carpet:   | Ok |
| Other:             | Ok |
| Walls / Outlets:   | Ok |
| Window:            | Ok |
| Window coverings:  | Ok |

| BATHROOM:          |                 |
|--------------------|-----------------|
| Cabinets / Mirror: | Ok              |
| Ceiling Lights:    | Ok              |
| Cleaning Bathroom: | Not Ok          |
| Charges Type       |                 |
| Charges            | 0               |
| Comment            | Needs cleaning  |
| Complete Toilet:   | Not Ok          |
| Charges Type       |                 |
| Charges            | 0               |
| Comment            | No toilet cover |
| Counter Top:       | Ok              |
| Floors:            | Not Ok          |

| Charges Type   |                |
|--|----------------|
| Charges  | 0              |
| Comment  | Needs cleaning |
| Formica /Tile:   | Ok             |
| Is there signs of moisture from outside in the apartment?: | Ok             |
| Other:   | Ok             |
| Remove Mildew on Tiles:                                    | Ok             |
| Shower Curtain Bar:  | Ok             |
| Shower Head:   | Ok             |
| Sink:  | Ok             |
| Soad Dish (Tub):   | Ok             |
| Soap Dish (Sink):  | Ok             |
| Toilet Paper Holder:                                       | Ok             |
| Toilet Tank:   | Not Ok         |
| Charges Type   |                |
| Charges  | 0              |
| Comment  | Needs cleaning |
| Towel Bar:   | Ok             |
| Tub Knob(s):   | Ok             |
| Tub Reglazing:   | Ok             |
| Vanity Cabinet:  | Ok             |
| Wall Outlets:  | Ok             |
| Window:  | Ok             |

| LOCKS:  |    |
|---|----|
| Door Knob:  | Ok |
| Door Lock:  | Ok |
| Ensure the apartment door has an automatic closure and closes properly. : | Ok |
| Fix Door when extra lock is removed:                                      | Ok |
| Mail-Box Lock:  | Ok |

| KEYS:                            |    |
|----------------------------------|----|
| Failure To Return Apartment Key: | Ok |
| Failure To Return Mailbox Key:   | Ok |

| DOORS:                               |    |
|--------------------------------------|----|
| Apartment Door:                      | Ok |
| Apartment Door closes automatically: | Ok |
| Frame:                               | Ok |
| Hollow:                              | Ok |
| Solid Core & Steel:                  | Ok |

| PAINTING:                     |    |
|-------------------------------|----|
| Border Removal (Per Room):    | Ok |
| Holes in Walls (Each Hole):   | Ok |
| Over Dark Colors (Per Room):  | Ok |
| Wallpaper Removal (Per Room): | Ok |

| CARPET:                   |    |
|---------------------------|----|
| Burns:                    | Ok |
| Deodorize:                | Ok |
| Pet Treatment (Odor):     | Ok |
| Replace Carpet 1 Bedroom: | Ok |
| Replace Carpet 2 Bedroom: | Ok |
| Shampoo 1 Bedroom:        | Ok |
| Shampoo 2 Bedroom:        | Ok |
| Stain Removal:            | Ok |

| MISCELLANEOUS:  |    |
|---|----|
| Broken Window Glass (Per Pane):   | Ok |
| Cabinet Equipment:  | Ok |
| Carbon Monoxide Detector:   | Ok |
| Cleaning of Apartment:  | Ok |
| Clear Storage Locker:   | Ok |
| Closet Shelves:   | Ok |
| Common Area damaged during moveout:   | Ok |
| Confirm you have installed or there is in place a stainless steel toilet tank water connector.: | Ok |
| Door Intercom System:   | Ok |
| Exhaust Fan:  | Ok |
| Fan Blades:   | Ok |

| Fire extinguisher:   | Ok |
|--|----|
| If fire stops have been installed throughout the property, ensure fire stops are installed.: | Ok |
| Light Globes:  | Ok |
| Mini Blind(s) each:  | Ok |
| Outside Lights:  | Ok |
| Phone Jack:  | Ok |
| Rallings:  | Ok |
| Removal Of Bulk Items:   | Ok |
| Remove Debris (Per Bag):   | Ok |
| Sliding Mirror/Glass Door (2):   | Ok |
| Smoke Detector Alarm:  | Ok |
| Stoppage by foreign object in any drain:   | Ok |
| Switch Plate Covers:   | Ok |
| Thermostat Cover:  | Ok |
| Vertical Blinds:   | Ok |
| Vinly Tile Bathroom:   | Ok |
| Vinly Tile Kitchen:  | Ok |
| Window Screen(s) each:   | Ok |
| Window Sills:  | Ok |

| OVERALL:                                 |    |
|--|----|
| Signs of Moisture inside the apartment:  | Ok |
| Signs of Moisture outside the apartment: | Ok |

| RENOVATED UNITS:  |    |
|---|----|
| All electrical boxes are to be secure in place and not hanging.:                          | Ok |
| Disposal and dishwasher are to be plug in and not hot hard wired.:                        | Ok |
| Do not overload the circuits.:  | Ok |
| Ground wires are to be hook up.:  | Ok |
| Make sure all wires are connected properly and tight and correct wire nut use.:           | Ok |
| No stabbing of wires into the back of outlet, they are to be put around the screw.:       | Ok |
| On GFCI outlets the hot wire goes to the line side on the fixture and not the load side.: | Ok |
| Plastic boxes are not to be surface-mounted, with a utility box.:                         | Ok |

| Install new 1/2 inch ball valves and remove the old gates valves.: | Ok |  |
|--|----|--|
| Removal of all sheetrock in the bathroom.:                         | Ok |  |
| Remove of old drums trap and installing P traps for tub drains.:   | Ok |  |
| Replace the 1/2 inch copper water lines.:                          | Ok |  |
| Using 1/2 inch hardi board around the wet area of the tub.:        | Ok |  |

## Cianni Hudson



| Technician                           | Cianni Hudson |
|--------------------------------------|---------------|
| Resident not available for signature |               |