

Make Ready Checklist Inspection

Inspection Date	Technician	Property	Units
12-19-2023	Andre Walker	Towers at Wyncote	0719-3

LIVING ROOM:	
Ceilings / Lights:	Ok
Door / Closet:	Ok
Other:	Ok
Plank Flooring:	Not Ok
Charges Type	
Charges	0
Comment	Damaged flooring needs to be swept and mopped



Walls / Outlets:	Ok
Window:	Ok
Window coverings:	Ok

DINING ROOM:	
Ceilings / Lights:	Ok
Plank Flooring:	Ok
Walls / Outlets:	Ok
Window:	Ok

Window coverings:	Ok
-------------------	----

KITCHEN:	
Backsplash:	Ok

Cabinets:	
Cabinet Door:	Ok

Cabinets:	
Cabinet Handle:	Ok

Cabinets:	
Cabinet Shelf:	Not Ok
Charges Type	
Charges	0
Comment	Dead roaches needs to be cleaned



Ceiling Fan:	Ok
Ceiling Light Fixture:	Ok
Ceiling Lights:	Ok
Cleaning of Stove:	Ok
Counter Top:	Ok

Dishwasher:	
Dishwasher Knob:	Ok

Dishwasher:	
Dishwasher Rack:	Ok

Dishwasher:			
Dishwasher Silverware Holder:		Ok	
Drip Pan:	Ok		
Electric Meter:	Ok		
Faucet:	Ok	Ok	
Faucet Knobs:	Ok	Ok	
Floors:	Ok	Ok	
Formica/Tiles:	Ok	Ok	
Garbage Disposal:	Ok		
Kitchen Sink:	Ok		
Microwave:	Ok		
Other:	No	Not Ok	
Charges Type			
Charges	0		
Comment	Flo	or dead roaches	



Oven / Range:	
Oven Cleaning:	Ok

Oven / Range:	
Oven door handle:	Ok

Oven / Range:	
Oven drip pan:	Ok

Oven / Range:	
Oven knobs:	Ok

Oven / Range:	
Oven Racks:	Ok

Oven / Range:	
Range burners:	Ok

Oven / Range:	
Range Hood:	Ok
Oven Door Handle:	Ok
Oven Racks:	Ok
Range Top:	Ok

Refrigerator (Freezer):	
Cleaning Refrigerator:	Not Ok
Charges Type	
Charges	0
Comment	Roaches



Refrigerator (Freezer):	
Refrigerator (Drawers):	Ok

Refrigerator (Freezer):	
Refrigerator (Shelf and Bars):	Not Ok
Charges Type	
Charges	0
Comment	Dead roaches



Refrigerator (Freezer):		
Refrigerator Crisper Glass/Plastic:		Ok
Rubber Stopper:	Ok	
Stove Knob:	Ok	
Verify that either a Fire Stop (under the microwave) or FireAvert (behind the stove) exists.:	Ok	
Wall Outlets:	Ok	
Washer/Dryer:	Ok	
Window Coverings:	Ok	

BEDROOMS:	
Ceilings / Lights:	Ok
Door / Closet:	Ok
Floors / Carpet:	Ok
Other:	Ok
Plank Flooring:	Ok
Walls / Outlets:	Not Ok
Charges Type	
Charges	0
Comment	Water damaged needs paint



Window:	Ok
Window coverings:	Ok

BATHROOM:	
Cabinets / Mirror:	Ok
Ceiling Lights:	Ok
Cleaning Bathroom:	Not Ok
Charges Type	
Charges	0
Comment	Not cleaned



Complete Toilet:	Ok
Counter Top:	Ok
Floors:	Not Ok
Charges Type	
Charges	0
Comment	Needs cleaning and mopped



Formica /Tile:	Ok
Is there signs of moisture from outside in the apartment?:	Ok
Medicine Cabinet:	Ok
Mirror Cabinet:	Ok
Other:	Not Ok
Charges Type	
Charges	0
Comment	Door need cleaning



Plank Flooring:	Ok
Remove Mildew on Tiles:	Ok
Shower Curtain Bar:	Ok
Shower Head:	Ok
Sink:	Ok
Soad Dish (Tub):	Ok
Soap Dish (Sink):	Ok
Toilet Paper Holder:	Ok
Toilet Tank:	Ok
Towel Bar:	Ok
Tub Knob(s):	Ok

Tub Reglazing:	Ok
Vanity Cabinet:	Not Ok
Charges Type	
Charges	0
Comment	Damaged not cleaned



Wall Outlets:	Ok
Window:	Ok

LOCKS:	
Door Knob:	Ok
Door Lock:	Ok
Ensure the apartment door has an automatic closure and closes properly. :	Ok
Fix Door when extra lock is removed:	Ok
Mail-Box Lock:	Ok

KEYS:	
Failure To Return Apartment Key:	Ok
Failure To Return Mailbox Key:	Ok

DOORS:	
Apartment Door:	Ok
Apartment Door closes automatically:	Ok
Frame:	Ok
Hollow:	Ok
Solid Core & Steel:	Ok

PAINTING:	
Border Removal (Per Room):	Ok

Holes in Walls (Each Hole):	Ok
Over Dark Colors (Per Room):	Ok
Wallpaper Removal (Per Room):	Ok


CARPET:	
Burns:	Ok
Deodorize:	Ok
Pet Treatment (Odor):	Ok
Replace Carpet 1 Bedroom:	Ok
Replace Carpet 2 Bedroom:	Ok
Shampoo 1 Bedroom:	Ok
Shampoo 2 Bedroom:	Ok
Stain Removal:	Ok

MISCELLANEOUS:	
Broken Window Glass (Per Pane):	Ok
Cabinet Equipment:	Ok
Carbon Monoxide Detector:	Ok
Cleaning of Apartment:	Ok
Clear Storage Locker:	Ok
Closet Shelves:	Ok
Common Area damaged during moveout:	Ok
Confirm you have installed or there is in place a stainless steel toilet tank water connector.:	Ok
Door Intercom System:	Ok
Dryer Vent Check water filled to level identified:	Ok
Exhaust Fan:	Ok
Fan Blades:	Ok
If fire stops have been installed throughout the property, ensure fire stops are installed.:	Ok
Light Globes:	Ok
Mini Blind(s) each:	Ok
Outside Lights:	Ok
Phone Jack:	Ok
Rallings:	Ok
Removal Of Bulk Items:	Ok

Remove Debris (Per Bag):	Ok
Sliding Mirror/Glass Door (2):	Ok
Smoke Detector Alarm:	Ok
Stoppage by foreign object in any drain:	Ok
Switch Plate Covers:	Ok
Thermostat Cover:	Ok
Vertical Blinds:	Ok
Vinly Tile Bathroom:	Ok
Vinly Tile Kitchen:	Ok
Window Screen(s) each:	Ok
Window Sills:	Ok

OVERALL:	
Signs of Moisture inside the apartment:	Ok
Signs of Moisture outside the apartment:	Ok

RENOVATED UNITS:	
All electrical boxes are to be secure in place and not hanging.:	Ok
Disposal and dishwasher are to be plug in and not hot hard wired.:	Ok
Do not overload the circuits.:	Ok
Ground wires are to be hook up.:	Ok
Make sure all wires are connected properly and tight and correct wire nut use.:	Ok
No stabbing of wires into the back of outlet, they are to be put around the screw.:	Ok
On GFCI outlets the hot wire goes to the line side on the fixture and not the load side.:	Ok
Plastic boxes are not to be surface-mounted, with a utility box.:	Ok



Technician	Andre Walker
Resident not available for signature	