



February 12, 2026

TOWERS AT WYNCOTE
309 YORK RD SUITE 211
JENKINTOWN PA 19046

Location: CEDARBROOK HILL APARTMENTS
8440 LIMEKILN PK
WYNCOTE PA 19095
Building Number: 30015 Equipment: 5

RE: NOTICE OF VIOLATION

On 02/04/2026, Inspector William Rapine conducted an inspection at the above-referenced location on equipment 5 and found violations of the Pennsylvania Construction Code Act (35 P.S. §§ 7210.101-7210.1103), The Uniform Construction Code (34 Pa. Code §§ 401.1-405.42) and the standards adopted for lifting devices. These violations are noted on the reverse side or second page of this letter.

You have **30 days** to correct these violations. Upon correcting the violations you shall check the following statement box below and then email this page to dmarchioni@pa.gov for a follow up inspection that confirms completion of the corrective action. All violations must be corrected prior to the issuance of a Certificate of Operation. Failure to correct these violations may result in the equipment being placed out of service and/or administrative fines under 35 P.S. § 7210.903 and 34 Pa. Code §§ 403.83-403.84.

ELEVATOR SAFETY BOARD PROCEDURE

ANY INDIVIDUAL AGGRIEVED BY THIS NOTICE MAY APPEAL TO THE PENNSYLVANIA ELEVATOR SAFETY BOARD. AN INDIVIDUAL MAY ALSO MAKE A REQUEST FOR AN EXTENSION TO COMPLY WITH THIS NOTICE AND/OR REQUEST A VARIANCE FROM THE APPLICABLE REGULATIONS AND TECHNICAL STANDARDS. ELEVATOR SAFETY BOARD FORMS ARE FOUND ON THE DEPARTMENT'S WEBSITE AT www.dli.pa.gov (KEY WORD: ELEVATOR SAFETY BOARD FORMS). WHEN FILING AN APPEAL OR REQUEST WITH THE ELEVATOR SAFETY BOARD, REFER TO THE FILE NUMBER FOUND ABOVE AND FULLY SET FORTH THE REASON FOR YOUR APPEAL, REQUEST FOR AN EXTENSION OF TIME, OR VARIANCE REQUEST. YOUR COMPLETED FORM MUST BE SENT TO: ELEVATOR SAFETY BOARD, 651 BOAS STREET, ROOM 1622, HARRISBURG PENNSYLVANIA 17121 ALONG WITH PAYMENT.

If you have any questions regarding this Notice, please contact Inspector William Rapine at (21-5) -545-6056.

Respectfully,

A handwritten signature in cursive script, appearing to read "David Marchioni".

David Marchioni, Elevator Division Director

☐ All violations have been corrected. Print name: _____ Signature _____
Date: _____

FINDING NO.1: UCC 405.7- INSPECTION REQUIREMENTS -All elevators are required to be inspected at intervals set forth in 405.7 of the UCC. When equipment is idle for extended period of time it is not subject to the requirements of this section if it is placed under state seal. When the inspector attempted to inspect the equipment listed above it was out of service and an inspection could not be conducted. Arrangements shall be made to have the equipment repaired and inspected or placed under state seal