

✘ Violation Notice and Order to Correct

L&I File Number: CF-2026-022569

RESPONSIBLE PARTY

York House North Partnership
309 York Rd
Ste 211
Jenkintown, Pennsylvania 19046

V1



DISTRICT OFFICE

Property Maintenance Unit
9359 Krewstown Rd
Philadelphia, PA 19115
215-685-0535
PropertyMaintenanceUnit@phila.gov

PROPERTY IN VIOLATION

1320 W SOMERVILLE AVE, Philadelphia, PA 19141-2913

DATE OF NOTICE

03/14/2026

On 03/13/2026 the Department of Licenses and Inspections inspected/investigated the property in violation and found the following condition(s) or activity which violate the Philadelphia Code. Based on these the property is deemed:

IN VIOLATION

The property will remain in this status until all the violations below are corrected and the Department of Licenses and Inspections has verified the corrective action. You are the person responsible for the correction of these violations.

Any permit or license obtained to comply a violation of working without or in excess of a permit or a license will result in an additional inspection fee equal to the cost of the permit or license. (Phila. Code § A-901.13)

YOU ARE ORDERED TO MAKE THE NECESSARY REPAIRS AND/OR TAKE THE NECESSARY ACTION(S) TO CORRECT THE CITED CONDITIONS PRIOR TO 04/17/2026


VIOLATIONS


PHILA. CODE §	FINE AMOUNT	SCAN QR CODE FOR HOW TO RESOLVE
F-901.6	\$300.00	
<p>PHILA. CODE LANGUAGE Fire detection and alarm systems, emergency alarm systems, gas detection systems, fire-extinguishing systems, mechanical smoke exhaust systems and smoke and heat vents shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Nonrequired fire protection systems and equipment shall be inspected, tested and maintained or removed.</p> <p>CONDITION IN VIOLATION REPAIR FIRE ALARM CURRENTLY IN TROUBLE MODE</p> <p>LOCATION 1320 W SOMERVILLE</p>		

✘ Violation Notice and Order to Correct

L&I File Number: CF-2026-022569

VIOLATIONS

PHILA. CODE §	FINE AMOUNT	SCAN QR CODE FOR HOW TO RESOLVE
F-903.5	\$300.00	
<p>PHILA. CODE LANGUAGE</p> <p>Sprinkler systems shall be tested and maintained in accordance with Section 901.</p>		
<p>CONDITION IN VIOLATION</p> <p>NEW SPRINKLER CERTIFICATION NEEDED CERTIFICATE MUST BE UPLOADED TO CITY ECLIPSE SYSTEM</p>		
<p>LOCATION</p> <p>1320 W SOMERVILLE</p>		

PHILA. CODE §	FINE AMOUNT	SCAN QR CODE FOR HOW TO RESOLVE
F-901.6.4	\$300.00	
<p>PHILA. CODE LANGUAGE</p> <p>The testing of fire protection systems shall be in accordance with Sections 901.6 and F-901.6.4 through F-901.6.4.8.1. Annually the owner of each building that contains fire protection systems shall have such systems certified as operating properly by a person certified or licensed by the Department of Licenses and Inspections to provide such certifications in accordance with this Section. Certification forms shall be maintained on the property and made available for inspection upon the request of a fire code official. The certification form shall be submitted to the Department of Licenses and Inspections which may, by regulation, establish a fee to be paid upon submission of the form.</p>		
<p>CONDITION IN VIOLATION</p> <p>NEW FIRE ALARM CERTIFICATION NEEDED CERTIFICATION MUST BE UPLOADED TO CITY ECLIPSE SYSTEM</p>		
<p>LOCATION</p> <p>1320 W SOMERVILLE</p>		

⚠ Failure to timely correct the violations listed above by or before the correction date listed above will result in the stated fine amount being imposed against you. The fines will be imposed on a per day basis for each violation that remains uncorrected AFTER the stated correction date. Phila. Code § A-601. If you timely correct each violation by the stated correction date, no fines will be due.

In addition to the fines listed above, failure to timely correct the violations will result in you being charged:

- Labor and material costs for any work performed by the City, such as a demolition; sealing of windows or doors; clearing of weeds, trash or debris; relocation expenses for removing occupants, costs associated with cease operations orders. Such costs are subject to an additional administrative fee of 21% (Phila. Code § A-503);
- An additional \$100 fee for repeat abatement work (Phila. Code § A-503.2); and
- Reinspection fees as follows: \$100 for the third inspection, \$200 for the fourth inspection, and \$350 for any additional inspections (Phila. Code § A-901.12.2).

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-022569



YOU HAVE THE RIGHT TO APPEAL THIS NOTICE. YOUR APPEAL MUST BE FILED BY 04/13/2026.

IF YOU DO NOT TIMELY FILE AN APPEAL THEN YOU WAIVE YOUR RIGHT TO LATER CHALLENGE ANY PART OF THIS NOTICE. This includes waiving your right to argue: whether the violations existed, whether you were responsible to correct the violations, whether you had enough time to correct the violations, whether the City should have abated the violations, and whether the City can impose fines, fees, or costs against you.

For more information on filing an appeal and/or to obtain the approved form visit the appeals section of the Department of Licenses and Inspections website at www.phila.gov/li or the Boards Administration Unit, Concourse Municipal Services Building, 1401 J.F.K. Blvd., Philadelphia PA.

Appeals of the Technical Codes, such as the Zoning Code and/or Fire Code, need to be submitted to the appropriate Technical Appeal Board such as the Zoning Board of Adjustment and/or the Board of Safety and Fire Prevention. For additional information call 215-686-8686.

IF YOU HAVE ANY LEGAL QUESTIONS YOU SHOULD CONSULT WITH AN ATTORNEY.

If you do **not have** an **attorney**, you **can contact** the Philadelphia Bar Association Referral and Information Line at 215-238-6333 **to have** an **attorney referred to you**. You can also find a list of legal aid service providers at <http://palegalaid.net/legal-aid-providers-in-pa>.



The Philadelphia Code may be found online for free at www.phila.gov under "Open government."

If you have any questions regarding this notice or would like to schedule a re-inspection, please contact: NATHANIEL WILLIAMS NathanielM.Williams@phila.gov or the district office noted above.

ATTENTION: This is an important notice! For information in your language, call 215-686-8686

ATENCIÓN: ¡Este es un aviso Importante! Para recibir información en su idioma, llame al 215-686-8686

注意: 这是重要通知! 如果您需要以您的语言获得此信息, 请致电 215-686-8686

CHÚ Ý: Đây là thông báo quan trọng! Nếu bạn cần thư này bằng ngôn ngữ khác, vui lòng gọi 215-686-8686

주의: 중요 통지입니다! 이 서신을 귀하의 언어로 받고 싶으시면 215-686-8686번으로 전화하시기 바랍니다

پر کال کریں 215-686-8686 ترجمے کی خدمات کے لیے! یہ ایک ضروری اطلاع نامہ ہے: توجہ فرمائیں

ATTENTION: Cet avis est important! Si vous avez besoin de cet avis dans une autre langue, appelez le 215-686-8686